

April 4, 2011

Proximity Sensors

No. 2011118E

**Discontinuation Notice of Proximity Sensor.
E2CY-T11**

Product Discontinuation

Recommended Replacement



Model E2CY-T11

Model E2CY-SD11

Discontinuation date : The end of October, 2011

Caution on recommended replacement

- The active indication is four digits display.
- The current consumption specification is 5mA higher.
- Sensitivity can also be set by the manual operation.
- The sensing head of the present E2CY can be used.
- There is no line of the self-diagnosis output.

Difference from discontinued product

Model	Body Color	Dimensions	Wire connection	Mounting Dimensions	Characteristics	Operation ratings	Operation methods
E2CY-SD11	--	*	*	**	*	*	--

** : Fully compatible

* : The change is a little/Almost compatible

-- : Not compatible

- : No corresponding specification

Product Discontinuation and recommended replacement

Product discontinuation	Recommended replacement
E2CY-T11	E2CY-SD11



Body color

Product discontinuation	Recommendable replacement
Gray	Black

Wire Connection

Product discontinuation E2CY-T11	Recommendable replacement E2CY-SD11
-	There is no line of the self-diagnosis output.

Mounting dimensions

Product discontinuation E2CY-T11	Recommendable replacement E2CY-SD11
 <p>2-M3 16</p>	 <p>2-M3 16</p>

Characteristics

Product discontinuation E2CY-T11	Recommendable replacement E2CY-SD11
Current consumption : 40mA or less. Display : Ten dots LED. Self-diagnosis: indication and output	Current consumption : 45mA or less. Display : One dot LED and Four digits. Self-diagnosis : indication

Operation methods

Product discontinuation E2CY-T11	Recommendable replacement E2CY-SD11
Sensitivity setting Teaching	Sensitivity setting Teaching and manual operation